From: "joel" <joel@advancedburner.com>
To: "Phil Hailes" <Phil-H@ipsc.com>
Date: Thu, Sep 11, 2003 1:57 PM
Subject: Re: PA Mass Flow

Ok you got me. My hands are not keeping up with my brain today!
210,000.

----- Original Message -----
From: "Phil Hailes" <Phil-H@ipsc.com>
To: <joel@advancedburner.com>
Sent: Thursday, September 11, 2003 2:54 PM
Subject: Re: PA Mass Flow

> Speaking of typo's.....21000 lb/hr is not correct for mills of this
> size.
>
> >>> "joel" <joel@advancedburner.com> 9/11/2003 12:58:07 PM >>>
> OK: You initially had lb/hr I did know if that was a typo or just the
> wrong
> number.
>
> We'll use 210,00 lb/hr as the design flow for the fuel injector
> sizing.
>
> Thanks,
>
> When do you need the dwg info you asked for?
>
>
> ----- Original Message -----
> From: "Phil Hailes" <Phil-H@ipsc.com>
> To: <joel@advancedburner.com>
> Sent: Thursday, September 11, 2003 2:04 PM
> Subject: Re: PA Mass Flow
>
>
> > 3500 lbs/min is the average rate that Unit 1 at 950 MW is running
> at
> > today with 7 mills. What specified condition are you requesting?
> >
> > >>> "joel" <joel@advancedburner.com> 9/11/2003 12:08:23 PM >>>
> > Phil: this number is not correct. PA flow for mills of this size is
> in
> > the
> > 100,000's lb.hr per mill.
> >
> > It is not an approximate value we need; but the actual quantity
> under
> > the
> > specified condition.
> >
> > Please recheck this.
> >